

Preliminary Assessment Report

Project 6458076, 335 25TH AVE E

Assessment Completed: 2/19/2015

Project Description: Construct new single family home.

Primary Applicant: [Dan Umbach](#)

This report lists the results of a preliminary assessment of your project requirements by various city departments. It's based on the project characteristics described on your site plan and preliminary application form. If your project required a pre-application site visit (PASV), the results of that site visit are also included. The goal of this report is to help you create a complete submittal package and reduce the need for corrections once your application has been submitted.

Next Steps

1. Review the requirements in this report and contact the staff members listed below with questions.
2. If a street improvement plan is required, develop and submit it to the Seattle Department of Transportation (SDOT). **The Department of Planning and Development (DPD) will not accept your permit application until your street improvement plan is approved as 60% complete by SDOT. See [SDOT Client Assistance Memo 2213](#) for guidance about the 60% complete approval process.**
3. Schedule an appointment for permit application intake with DPD. **Please bring a copy of this report to your intake appointment.**

Questions About This Report

If you have questions about the information in this report, contact the appropriate city staff member for each section.

DPD Drainage Requirements

Arthur Thomas Richardson, (206) 684-3655, art.richardson@seattle.gov

DPD Land Use Requirements

Malli Anderson, (206) 233-3858, Malli.Anderson@Seattle.Gov

DPD Preapplication Site Visit Requirements

Keller Rockey, (206) 684-7914, Keller.Rockey@seattle.gov

Seattle City Light Requirements

Ray Ramos, (206) 615-1193, ray.ramos@seattle.gov

Seattle Department of Transportation Requirements

Joel Prather, (206) 615-0772, joel.prather@seattle.gov

Seattle Public Utilities Requirements

Jim Mahady, (206) 684-5950

Water Availability

SPU Staff, (206) 684-3333, SPUWaterAvailability@Seattle.Gov

Other Resources

- General questions about the permit process: Contact the DPD Applicant Services Center (ASC) at 206-684-8850.
- User-friendly guides to city permitting processes: [DPD](#) and [SDOT](#).
- [Detailed zoning information](#).
- Visit our [permit type pages](#) for step-by-step instructions and forms for preparing your application and plans for review.

Requirements

DPD Drainage Requirements

The following requirements are based on the current stormwater and side sewer codes.

Existing Public Drainage Infrastructure

Sanitary sewer main location: 25th Ave E

Sanitary sewer main size: 8-inch

Storm drainage main location: 25th Ave E

Storm drainage main size: 15-inch

Drainage

The drainage point of discharge (SMC 22.805.020) is located at: Weep hole.

Flow Control Compliance

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water quality per SMC 22.805.020.E. A completed [Construction Stormwater Control and Soil Amendment Standard Plan](#) is required.

Submit a [Standard Drainage Control Plan for Small Projects](#) including the [Green Stormwater Requirement Calculator](#).

For projects with 5,000 square feet or more of new plus replaced impervious surface, a comprehensive drainage control plan and construction stormwater control plan shall be prepared by a licensed engineer.

Water Quality

No requirements

Wastewater

An extension of the public sanitary sewer is required (SMC 21.16.260).

This mainline extension is eligible to enter into a Latecomer Agreement. Latecomer agreements allow a property owner who has installed water or sewer utility system improvements to recover a portion of the costs of those improvements from other property owners who later connect to the improvements. For more information, please visit our website at http://www.seattle.gov/util/Engineering/Consulting_Resources/LatecomerAgreements/index.htm or call SPU's Development Services Office at 206-684-3333.

The site is designated as a high probability of having a Special Sewer Connection Charge (SMC 21.24.030). If a charge is required, a "[Special Sewer Connection Charge Contract](#)" must be executed by the applicant prior to side sewer permit issuance.

All homeowners and building owners in King County's service area whose home or building was newly connected to the King County sewer system on or after Feb. 1, 1990 must pay a [King County Capacity Charge](#).

Permanent and Temporary Dewatering

The footing drain (if part of building plan) point of discharge ([DPD DR 4-2011](#)) is located at the following:
Built-As Combined Sewer.

DPD Land Use Code Requirements

Street Requirements

Based on the scope of the proposed project, the following street improvements are required per Chapter 23.53 of the Seattle Municipal Code. Please review Right-of-Way Improvements Manual for design criteria (<http://www.seattle.gov/transportation/rowimanual/manual/>). Show required street improvements on your "enhanced site plan" at DPD permit application intake. If an SDOT Street Improvement Plan (SIP) is required, please list SDOT project number and SDOT contact name on the enhanced site plan. Street Improvement Plans must be accepted by SDOT prior to DPD permit application intake.

25TH AVE E

Based on the documents provided, no street improvements are required per SMC 23.53.015 and SMC 23.53.006

New structures must be designed to accommodate right-of-way improvements. To ensure that driveways and pedestrian access points are designed to match these future street improvements, please use the Building Grade Calculator, which can be found at <http://www.seattle.gov/transportation/gradesheetintro.htm>

Because full street improvements are not being required for this project, or the project qualifies for a reduced street improvement, a no-protest agreement is required. This form can be found [here](#).

Land Use

Preliminary screening of your project has been completed and it appears that your proposal is located in an environmentally critical area (ECA) which may require an ECA review and SEPA. For additional information about ECAs and SEPA, visit the DPD website (<http://www.seattle.gov/dpd/Codes/>).

Based on the preliminary scope, the project may qualify for a specific exemption under the Environmentally Critical Areas Ordinance. Application and decision on the exemption must be made before submittal of a application. See CAM 327 for more details.

Other Requirements: Site is mapped as 40 percent steep slope environmentally critical area.

Pre-Application Site Visit (PASV) Requirements

PASV report requirements may be subject to additions, changes, or modifications by the department. The purpose of the report is to alert the applicant that there may be unusual or complex site conditions that trigger requirements from the department regarding this project. **The applicant is responsible for providing all required documents at the intake appointment.** If you have questions about this report or the PASV process, please contact the DPD Site Development Team at (206) 684-8860.

Note: Any project application associated with the development site can utilize the results from this PASV if the application is accepted by DPD within 24 months of the above inspection date. After 24 months, the applicant must apply for another PASV. No extensions will be granted.

ECA Mapping Unit and Type

This project site appears to include the following ECAs and/or buffers:
Steep slope

Earth Disturbance

This field assessment found evidence of previous grading or unstable soils. Please provide a soils report.

If excavation has the potential to encroach on adjacent property in order to facilitate construction activity, please provide documentation of consent from the adjacent property owner. Show area of proposed encroachment on the submitted drawings and detailed cross-sections.

If temporary cuts greater than 1h:1v will be required in order to facilitate construction activity, please provide a geotechnical engineer's verification that soil conditions allow cuts to stand unsupported. Include detailed cross sections.

Please show all existing and proposed retaining walls/rockeries and the exposed height.

If shoring will be required, please provide submittals by geotechnical and structural engineers and show the proposed system on the submitted drawings. Include detailed cross sections.

Potential Impacts to Seattle Parks Property

No parks property in vicinity

Tree Protection

Trees greater than 6 inches in diameter as measured 4.5 ft above ground are present on the site but not shown on the site plan. Show the dripline of

- 1) **all** trees on the site,
- 2) adjacent trees that encroach on the site that are greater than 6 inches in diameter as measured 4.5 ft above ground, and
- 3) **all** trees located in the adjacent ROW.

Include common and scientific names for all trees shown. For more information, see [Director's Rule 16-2008](#) and [Tip 242](#).

Construction Stormwater Control

All projects with earth disturbance, regardless of size, require temporary and permanent stormwater control in accordance with the Construction Stormwater Control (CSC) Technical Requirements Manual ([DR 16-2009, Volume 2](#)).

Show the following on the [Construction Stormwater Control and Soil Amendment Standard Plan](#):

Place compost socks, compost berms, filter fabric fencing, straw bales, straw wattles, or other approved perimeter control BMPs to eliminate construction stormwater runoff.

Show the location of a stabilized construction access to the site; show methods to eliminate uncontrolled conveyance of mud and dirt into the right of way (ROW).

Place silt-trapping inserts in receiving catch basins located within 10 feet of construction entrance.

Cover bare soil with compost blankets, straw, mulch, matting, or other approved equal to control construction stormwater runoff.

Cover stockpiles and bare slopes with compost blankets, tarps, matting or other approved equal to control construction stormwater runoff.

A First Ground Disturbance inspection is required before any ground disturbance related to this permit, including demolition, tree cutting, clearing, grubbing, and grading. After your permit is issued, schedule an inspection by calling (206) 684-8900 or [online](#) at <http://web1.seattle.gov/DPD/InspectionRequest/default.aspx>.

Standard Submittal Requirements for Projects in an ECA

Submit a geotechnical report with the permit intake submittal package. Geotechnical report must be signed and stamped by a geotechnical engineer licensed in the State of Washington per [SMC 22.170.070](#), [SMC 25.09](#), and [Directors Rule \(DR\) 18-2011](#).

Provide a topographic survey with 2-foot contours on and within 25-feet of the property, stamped by a licensed land surveyor (see [25.09.330A](#))

Delineate the clearing limits on the site plan

Provide a vegetation restoration plan per SMC [25.09.320](#), [Tip 331](#) and [Tip 331A](#). **Prior to any vegetation removal in the critical area, review, approval, and a preconstruction meeting is required**

Delineate the steep slope critical area on a site plan based on the survey (per SMC 25.09.020 A3b(5)). Provide area calculations for the steep slope delineation.

Show the steep slope buffer. Generally, the buffer is 15-feet from the top and/or toe of the slope

Construction activity area appears to be within the steep slope critical area and/or its associated buffer. A steep slope variance may be required (see SMC 25.09.180E.1)

An ECA pre-submittal conference is strongly recommended. Call the Applicant Services Center (206-684-8850) to schedule an appointment

Seattle City Light Requirements

Easements

SCL power easement is required. Property survey may be required at project's expense. An easement over 333 is required to provide electrical service to 335.

SCL blanket power easement over the entire parent parcel may be required. Property survey may be required at project's expense. If this is a unit lot subdivision, a blanket easement is needed.

Other requirements: At the time of this review, SCL has not received or reviewed an application for short subdivision or lot boundary adjustment. The parent parcel is considered one site and SCL's single-service rule applies. It is highly recommended that the project contact an SCL Electrical Service Representative to discuss SCL's requirements for electrical service connection and to confirm a viable easement location.

Notes to Applicant

For new service, please contact the Electrical Service Representative for your area several months before new service is required to determine your electric service design, service location and what kind of service is available at the building site. An Application for Electrical Service must be submitted to Seattle City Light. The Electrical Service Representative should also be contacted to coordinate temporary power for construction. Your Electrical Service Representative is: Patty Breidenbach, 206-684-4795, patty.breidenbach@seattle.gov. Be advised that it is the applicant's responsibility to seek guidance from SCL. Failure to contact SCL early in the permit process could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

SDOT Requirements

The City of Seattle's Right-of-Way Improvements Manual (ROWIM) and SDOT's Street & Sidewalk Pavement Opening and Restoration (PORR) Director's Rule 2004-02 may be accessed from SDOT's Street Use website at: http://www.seattle.gov/transportation/stuse_docs.htm. Whenever possible, specific reference notation for these two design documents is noted next to the design characteristics below. Be advised that these specific section and chapter references are provided as preliminary guidance only and are not comprehensive in scope.

SDOT Permitting Information

Initial Review Deposit: \$2,500

SDOT Plan Requirements: Engineered plan

SDOT Permit Requirements: Group 3: Street Use Major (Type 45). A 60% complete street improvement plan (SIP) must be approved by SDOT prior to your DPD construction intake appointment. SIP Design Guidance is required for 60% complete SIP approval; apply early. Please visit SDOT's Street Use website at: http://www.seattle.gov/transportation/stuse_sip.htm to obtain SDOT Client Assistance Memos (CAMs) and application materials to assist in developing your street improvement plan (SIP).

Street Improvement Requirements

25TH AVE E

All improvements on private property must accommodate the right of way elevation at the property line using the standard cross-section in the ROWIM. Right of way grading may be required to provide vehicular and pedestrian access that meets the standard cross-section.

New/replacement sidewalk: See Seattle Right of Way Improvements Manual (ROWIM) as well as the City of Seattle Standard Plan 420, 421 and 422. Repair & restoration of existing as needed.

Other requirements: Public Sanitary Sewer Main extension per DPD.

SPU Requirements

Flow Control Compliance

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water quality per SMC 22.805.020.E. For projects with 5,000 square feet or more of new and replaced impervious surface, a comprehensive drainage control plan shall be prepared by a licensed engineer.

Water Availability

Your water availability assessment has been approved.

Water Availability Certificate reference number: 20150252

Water Availability Certificate status: Approved with No Changes

Prepared by: Richard F Wilson

Existing Water System Information

Proximity of nearest fire hydrant is: 175 feet NE of property. Meets standards.

Water Main:

Size: 8 inches

Material: Cast Iron

Class: A

- Standard

- Abutting

Water Main is available to serve in: 25th Avenue E

Distance of main to W margin of street is 43 feet.

Public ROW width is 66 feet.

Water Service(s):

Other Requirements

Owners of residential property occupied by a tenant who will be displaced by housing demolition, substantial rehabilitation, change of use, or removal of use restrictions may need to obtain a Tenant Relocation License. Refer to DPD Tip 123, Seattle's Tenant Relocation Assistance Ordinance, for further information and instructions or call (206) 684-7979.

If your project involves additions or modification to or demolition of an existing building that contains four or more dwelling units or 4,000 square feet or more of non-residential area, and the building is a designated historic landmark or is 50 years old and meets the criteria set forth in SMC 25.12 for landmark designation, SEPA is required. Please contact the Department of Neighborhoods at (206) 684-0228 or www.seattle.gov/neighborhoods/preservation to determine if your building is a designated landmark or if a

referral is necessary to determine if the building meets the criteria in SMC 25.12. Refer to Tip 208 for information regarding the application requirements for a SEPA review and Tip 3000 for information regarding landmarks and historic preservation.

If the scope of your proposed project changes before your DPD intake appointment or SDOT street improvement plan application, the requirements in this report may change. If there are municipal code and ordinance changes before our DPD intake appointment, the project must meet the new code requirements. Additional street improvement requirements may be triggered if a permit application for a development project on adjacent property is also undergoing review.

Please be aware that all persons or companies working within the City limits, including all contractors, subcontractors, permit expeditors and other service providers are required to possess a valid City of Seattle business license. This license is required in addition to any other licenses required by the State of Washington, such as a contractors' license or state business license. For more information about City of Seattle business licenses, please contact inspector Michale Crooks at 206-684-8871, Michale.Crooks@seattle.gov, or visit the [Licensing and Tax Administration Division website](#).